

Deseret Power's Quarterly
Local Transmission Planning Public Meeting
September 29, 2011

Attendance:

Jim Tucker, Deseret Power Transmission
Clay Macarthur, Deseret Power Merchant
Scott Lynsky, UMPA

Introductions:

Local Planning Process:

The Local Planning Process for 2011 was discussed. The completed NERC TPL standards assessment was discussed. This year the TPL studies were evaluated on the 2012HS3 near term case and the 2016HW2a long term case. The addition of the 500 kV Gateway south line made it more difficult to load the Bonanza West path especially with the counter schedules to serve the Chipeta load. As a result two scenarios were required for the long term studies. The final results were very similar to last years results. A new plant operating procedures was put in place to allow for more VAR capacity under heavy loading conditions.

There were no comments or suggestions for the future studies.

No other business or suggestions were discussed.

The next meeting will be in December of 2011.