

Criteria for Notification of Network Customer Load Changes

Information and Updates

Sections 30.2 and 32.1 of the LG&E/KU OATT require each Network Customer to submit to the ITO a 10 year Network Load forecast of summer and winter peak load (real and reactive) at each delivery point and a Network Resource forecast as part of their Service Agreement Application. Section 32.7 of the Tariff requires all Network Customers will provide the ITO with annual updates of Network Load and Network Resource forecasts consistent with those included in the Application for Network Integration Transmission Service.

Additionally, in accordance with Section 32.7 of the Tariff, the Network Customer shall provide the ITO with timely written notice of material changes in any other information provided in its Application relating to the Network Customer's Network Load, Network Resources, its transmission system or other aspects of its facilities or operations affecting the Transmission Owner's ability to provide reliable service.

Modifications of Existing Delivery Point Forecast

The ITO must be notified when there is a material change to the load of an existing delivery point that is represented in a Network Customer's existing Service Agreement. A material change in the delivery point load forecast is defined as:

- The actual seasonal peak load deviates from the most recent forecast provided to the ITO by 10% or greater.
- The forecasted seasonal peak load deviates from the most recent forecast provided to the ITO by the greater of:
 - a) more than 3% in any one year or
 - b) more than 1 MW in any one year.
- The annual growth rate of the forecasted seasonal peak load deviates from the most recent forecasted annual growth rate provided to the ITO by more than 1%.

A System Impact Study will be performed by the ITO in cases where the reported increase in any of the first seven years exceeds 2 MW at 69 kV (4 MW at 138 kV or 161 kV) or exceeds 4 MW at 69 kV (8 MW at 138 kV or 161 kV) in any of the following years.

Modifications of Existing Delivery Point Configuration

Any change in the delivery point configuration reported in the Network Operating Agreement (Attachment G) must be provided to the ITO and Transmission Owner.

New Network Loads

According to section 32.2 of the Tariff, network customers will provide the ITO with advance notice of any new load addition via a new OASIS reservation and application. Such notification will require the ITO to perform a System Impact Study in accordance with Section 33 of the Tariff.