

# Manitoba Hydro

## Dispatch Log: All

Between 05/06/2016 0000 And 05/06/2016 2359

Page 1 of 3

| <i>Time</i> | <i>Log Entry</i>  |      |                 |
|-------------|---|------|-----------------|
| 0000        | TLR: LEVEL: 3A, START: 05/06/2016 0000, END: 05/06/2016 0100, MH: 192 MW, ID: 21150<br>192 MWH<br>Friday, May 6, 2016   | GSO  | Timothy Wilson  |
| O 0022      | ACTUAL START DATE/TIME: 05/06/2016 0022<br>ACTUAL END DATE/TIME: 05/06/2016 0034<br>STATION: WHITESHELL - 230-115KV<br>EQUIPMENT: BANK 7 OL 3-2<br><br>REMARKS :<br>Friday, May 6, 2016   | NSSS | Lewis, David    |
| 0028        | JOEY WOLFE CALLED BACK IN REGARDS TO THE BUILDING TEMP ALARM AT BERENS. WILL FOLLOW UP TOMORROW TO SCHEDULE A FLIGHT OUT TO ENSURE BUILDING IS SET UP FOR THE SUMMER, IE TURN THE AC ON.<br>Friday, May 6, 2016   | STO1 | Boiteau, Jeremy |
| O 0037      | ACTUAL START DATE/TIME: 05/06/2016 0037<br>ACTUAL END DATE/TIME: 05/06/2016 0049<br>STATION: WHITESHELL - 230-115KV<br>EQUIPMENT: BANK 8 OL 3-2<br><br>REMARKS :<br>Friday, May 6, 2016   | NSSS | Lewis, David    |
| 0100        | TLR: LEVEL: 3A, START: 05/06/2016 0100, END: 05/06/2016 0200, MH: 470 MW, ID: 21150<br>470 MWH<br>Friday, May 6, 2016   | GSO  | Timothy Wilson  |
| 0135        | CALL OUT: DATE/TIME: 05/06/2016 0135, PERSON CALLED: BRAD WOODFINE, REASON: TELENIIUM ALARMS UP AT POINTE DU BOIS AND MAC. LEFT A MESSAGE, BRAD IS NOT ON CALL BUT COULD NOT ACCESS THE COMMUNICATIONS STANDBY LIST FOR UPDATED ONCALL PERSON.<br>Friday, May 6, 2016 | STO1 | Boiteau, Jeremy |
| 0148        | CALL OUT: DATE/TIME: 05/06/2016 0148, PERSON CALLED: JIM LAW, REASON: TELENIIUM ALARMS AT POINTE DU BOIS AND MAC. CAN'T ACCESS STANDBY LIST TO FIND OUT WHO IS ON CALL SO I CALLED THE SUPERVISOR, NO ANSWER LEFT A MESSAGE. CALLED HOME.<br>Friday, May 6, 2016      | STO1 | Boiteau, Jeremy |
| 0200        | TLR: LEVEL: 3A, START: 05/06/2016 0200, END: 05/06/2016 0300, MH: 314 MW, ID: 21150<br>314 MWH<br>Friday, May 6, 2016   | GSO  | Timothy Wilson  |
| 0209        | CALL OUT: DATE/TIME: 05/06/2016 0209, PERSON CALLED: ROD BOUVIER, REASON: TELENIIUM ALARMS AT POINTE DU BOIS AND MAC.<br>JIM LAW CALLED BACK TO INFORM THAT ROD WAS ON CALL.<br>Friday, May 6, 2016   | STO1 | Boiteau, Jeremy |
| 0300        | TLR: LEVEL: 3A, START: 05/06/2016 0300, END: 05/06/2016 0400, MH: 205 MW, ID: 21150<br>205 MWH<br>Friday, May 6, 2016   | GSO  | Timothy Wilson  |

# Manitoba Hydro

## Dispatch Log: All

Between 05/06/2016 0000 And 05/06/2016 2359

Page 2 of 3

| <i>Time</i> | <i>Log Entry</i>  |      |              |
|-------------|---|------|--------------|
| 0524        | BERENS RIVER HIGH TEMP ALARM NORMAL<br>Friday, May 6, 2016  | STO1 | Frost, Joel  |
| 0820        | CUSTOMER MAGELLAN CALLED FOR A COMPLAINT OF LOW VOLTAGE. THEY ARE CURRENTLY BEING FED OFF OF J13. ROSSER 115 KV VOLTAGE WAS TAPPED UP TO RAISE ST. JAMES 24 KV BUS 4 VOLTAGE. CONTACT IS STEVE AT 775-8331 EXT. 3433.<br>Friday, May 6, 2016  | STO1 | Chase. Heath |
| 1115        | CALL OUT: DATE/TIME: 05/06/2016 1015, PERSON CALLED: DEREK DOERKSEN, REASON: KING STATION 66-12 KV BANK 2 LTC FILTER ALARM. NORMAL AT 1100<br>Friday, May 6, 2016   | STO1 | Chase. Heath |
| 1248        | CURTAILED TAG ONT_MAG0011204660_MISO FROM 63 MW TO 0 MW FOR HE14 DUE TO OVER SCHEDULE LIMITS ON US INTERFACE.<br>Friday, May 6, 2016  | GNSO | Gerald, Ross |
| 1535        | OVERSCHEDULE BY 21 MW ON US INTERFACE FROM 1500 TO 1520 DUE TO ONT - MISO WHEEL TAGS COMING IN AT 14:53 TO START ON THE QUARTER HOUR.<br>Friday, May 6, 2016  | GNSO | Gerald, Ross |
| ○ 1800      | ACTUAL START DATE/TIME: 05/06/2016 1800<br>ACTUAL END DATE/TIME:<br>STATION: POINTE DU BOIS G.S.<br>EQUIPMENT: GENERATOR 14<br><br>AFFECTED :<br>STATION: CUSTOMER COUNT: 0 MINUTES: 0<br><br>EVENT DESCRIPTION: WAITING FOR INSULATION TESTING TO BE COMPLETE. ORIGINAL ORDER IS 16-00369<br><br>Friday, May 6, 2016 | NSSS | Gerald, Ross |
| ○ 1833      | ACTUAL START DATE/TIME: 05/06/2016 1833<br>ACTUAL END DATE/TIME: 05/13/2016 1849<br>STATION: WHITESHELL - 230-115KV<br>EQUIPMENT: BANK 8 OL 2-3<br><br>REMARKS :<br>Friday, May 6, 2016   | GNSO | Kuzma, Dan   |

# Manitoba Hydro

## Dispatch Log: All

Between 05/06/2016 0000 And 05/06/2016 2359

Page 3 of 3

| <i>Time</i> | <i>Log Entry</i>  |
|-------------|---|
| O 1843      | ACTUAL START DATE/TIME: 05/06/2016 1843<br>ACTUAL END DATE/TIME:<br>STATION: HERBLET LAKE<br>EQUIPMENT: LINE HS23<br><br>AFFECTED :<br>STATION: SHERRIDON CUSTOMER COUNT: 0 MINUTES: 0<br>STATION: SHERRIDON CUSTOMER COUNT: 80 MINUTES: 0<br><br>EVENT DESCRIPTION: 115 KV BREAKERS R23/R24 TRIPPED OPEN WITH AN UNSUCCESSFUL RECLOSE.<br>DANNY DAY (MANAGER LINE MAINTENANCE) WAS CALLED AND IS ORGANIZING AN AIR PATROL.<br>CUSTOMER SERVICE IS ALSO LOOKING AT PUTTING THE GENERATORS ON AT SHERRIDON.<br>STRUCTURE 114 HAD A BURNT POLE, THAT NEEDS TO BE REPLACED.<br>Friday, May 6, 2016 <span style="float: right;">GNSO</span> <span style="float: right;">Van Den Driessche, Rodrick</span> |
| C 1855      | CALL OUT: DATE/TIME: 05/06/2016 1904, PERSON CALLED: STANDBY, REASON: KETTLE PRIMARY - G8 EXCITATION ALARM. EXCITER FAN 1 OF 2 FAILED. WILL RUN WITH 1 FAN. IF 2ND FAN FAILS UNIT WILL 86. THEY HAVE FANS AT THE STATION IF DOES FAIL AND THEY HAVE TO REPAIR.<br>Friday, May 6, 2016 <span style="float: right;">GSO</span> <span style="float: right;">Ray Berendse</span>  |
| C 2019      | CALL OUT: DATE/TIME: 05/06/2016 2019, PERSON CALLED: JARROD ERLENDSON, REASON: SOUTHWOOD EQUIPMENT ALARM<br>Friday, May 6, 2016 <span style="float: right;">STO2</span> <span style="float: right;">Scott, Derek</span>   |
| 2130        | ED DANYLUK, THOMPSON CSC MANAGER GAVE HIS APPROVAL THAT SHERRIDON CUSTOMERS WERE GOING TO BE ON STAND BY GENERATORS UNTIL TUESDAY. THIS IS DUE TO LINE MAINTENANCE WORKING ON THE DC OUTAGE.<br>Friday, May 6, 2016 <span style="float: right;">STO1</span> <span style="float: right;">Van Den Driessche, Rodrick</span>   |
| 2242        | LSLR?HVDC REDN 230KV ALARM WAS UP SINCE YESTERDAY AT 1259. RIEL STAFFWERE CALLED TO TROUBLE SHOOT. NO PROBLEMS WERE FOUND AT RIEL AND THERE TELECONTROL TECH (GEARLD PACULAN) SAID THE ISSUE WAS PROBABLY AT SCC END. MAJIC PRCSHOP WAS CALLED. WENT THROUGH THE STATION TABULAR AND FOUND THAT THIS ALARM WAS NOT IN SERVICE. MAJIC SAID IT WAS OKAY TO CLEAR THE ALARM.<br>Friday, May 6, 2016 <span style="float: right;">STO1</span> <span style="float: right;">Van Den Driessche, Rodrick</span>  |
| H 2359      | DAILY TOTALS:<br>IMPORT: 1021 MW<br>EXPORT: 43903 MW<br>EM CALLS:<br>TLR: 3- 3A EXTERNAL 976 MW; 976 MWH<br>Friday, May 6, 2016 <span style="float: right;">GSO</span> <span style="float: right;">Ray Berendse</span>  |