

Manitoba Hydro

Dispatch Log: All

Between 05/08/2016 0000 And 05/08/2016 2359

Page 1 of 4

<i>Time</i>	<i>Log Entry</i>		
0030	GEOMAGNETIC DISTURBANCE WARNING K=7 OR GREATER EXPECTED 00:30 TO 04:00. Sunday, May 8, 2016	GSO	Ray Berendse
0059	GEOMAGNETIC ALERT K=7 THRESHOLD REACHED. Sunday, May 8, 2016	GSO	Ray Berendse
0211	CALL OUT: DATE/TIME: 05/08/2016 0211, PERSON CALLED: JOEY WOLFE, REASON: GULL LAKE HIGH/LOW TEMP ALARM Sunday, May 8, 2016	STO2	Scott, Derek
0240	ACTUAL START DATE/TIME: 05/08/2016 0240 ACTUAL END DATE/TIME: 05/08/2016 0255 STATION: WHITESHELL - 230-115KV EQUIPMENT: BANK 7 OL 3-2 REMARKS : Sunday, May 8, 2016	GNSO	Van Den Driessche, Rodrick
0259	ACTUAL START DATE/TIME: 05/08/2016 0259 ACTUAL END DATE/TIME: 05/08/2016 0307 STATION: WHITESHELL - 230-115KV EQUIPMENT: BANK 8 OL 3-2 REMARKS : Sunday, May 8, 2016	GNSO	Van Den Driessche, Rodrick
0400	GEOMAGNETIC DISTURBANCE WARNING TERMINATED Sunday, May 8, 2016	GSO	Ray Berendse
0532	CALL OUT: DATE/TIME: 05/08/2016 0532, PERSON CALLED: DAN TAMER, REASON: SPLIT LAKE MICROWAVE EQUIPMENT FAIL ALARM Sunday, May 8, 2016	STO2	Scott, Derek

Manitoba Hydro

Dispatch Log: All

Between 05/08/2016 0000 And 05/08/2016 2359

<i>Time</i>	<i>Log Entry</i>
O 0708	ACTUAL START DATE/TIME: 05/08/2016 0708 ACTUAL END DATE/TIME: 05/08/2016 0708 STATION: LAVERENDRYE EQUIPMENT: LINE 2 AFFECTED : STATION: CABOT CUSTOMER COUNT: 414 MINUTES: 0 STATION: CABOT CUSTOMER COUNT: 358 MINUTES: 0 STATION: ELIE CUSTOMER COUNT: 442 MINUTES: 0 STATION: ELIE CUSTOMER COUNT: 285 MINUTES: 0 STATION: HEADINGLEY CUSTOMER COUNT: 553 MINUTES: 0 STATION: ISOBOARD CUSTOMER COUNT: 1 MINUTES: 0 STATION: SANFORD CUSTOMER COUNT: 299 MINUTES: 0 STATION: SANFORD CUSTOMER COUNT: 515 MINUTES: 0 STATION: STARBUCK DSC CUSTOMER COUNT: 312 MINUTES: 0 EVENT DESCRIPTION: TRIP AND SUCCESSFUL AUTO-RECLOSE OF 66 KV LINE 2, TARGETS REQUIRED. Sunday, May 8, 2016 STO2 Whynot, Thomas
0736	DANIEL TAMER CALLED TO INFORM US THAT THE TELENIUUM ALARMS THAT ARE COMING IN FROM SPLIT LAKE ARE NOT CRITICAL ALARMS AND THAT THEY WILL BE TAKEN CARE OF DURING THE WORK WEEK. THE ALARMS ARE BEING GENERATED DUE TO A FAULTY CARD. IN THE MEANTIME, HE HAS CONTACTED KRIS WEGGERT, AND KRIS WILL BE DISABLING THE POINTS THAT ARE DRIVING THOSE ALARMS IN TO SCC. Sunday, May 8, 2016 GNSO Gerald, Ross
0855	PINE FALLS CONDUCTING SOME FIRE PUMP TESTS, WHICH WILL BE DRIVING IN FIRE ALARMS. THEY WILL CALL US WHEN THEY ARE COMPLETED THEIR WORK. AS PER MAURICE. Sunday, May 8, 2016 GNSO Gerald, Ross
0923	MISO WEEKLY 0 MW ARS TEST COMPLETED SUCCESSFULLY. Sunday, May 8, 2016 GNSO Gerald, Ross
1000	MISO MSAT CALL. SOUTH ROLL CALL ONLY. NO PARTICIPATION FROM MHEB REQUIRED. Sunday, May 8, 2016 NSSS Joseph Richard
C 1222	CALL OUT: DATE/TIME: 05/08/2016 1222, PERSON CALLED: JARROD ERLENDSON, REASON: TSM SECURITY CALLED TO INFORM US OF AN ALARM AT LAVERENDRYE AND THAT CAMERA 12 HAS LOST IT'S FEED, JARROD WILL PICKUP ANOTHER STAFF MEMBER TO ACCOMPANY HIM TO CHECK THE STATION. 204-999-8273 Sunday, May 8, 2016 GNSO Whynot, Thomas

Manitoba Hydro

Dispatch Log: All

Between 05/08/2016 0000 And 05/08/2016 2359

Page 3 of 4

<i>Time</i>	<i>Log Entry</i>		
O 1403	ACTUAL START DATE/TIME: 05/08/2016 1403 ACTUAL END DATE/TIME: 05/08/2016 2056 STATION: POINTE DU BOIS G.S. EQUIPMENT: P3 POINTE DU BOIS - ROVER AFFECTED : STATION: CUSTOMER COUNT: 0 MINUTES: 0 EVENT DESCRIPTION: TRANSIENT FAULT ON P3 WITH UNSUCCESSFUL MANUAL RECLOSE. A BROKEN INSULATOR WAS FOUND AND REPLACED.		
	Sunday, May 8, 2016	NSSS	Scott, Derek
1430	INITIATED SPILL AT LONG SPRUCE AND LIMESTONE DUE TO POLE 3 OUTAGE AND L/R TRANSFER LIMIT PREVENTING 2 UNITS AT EACH PLANT FROM OPERATING. Sunday, May 8, 2016		
	Sunday, May 8, 2016	GSSS	Jeff Kergen
1449	CALL OUT: DATE/TIME: 05/08/2016 1449, PERSON CALLED: BRENT MORGAN, REASON: SWITCHING FOR P3 TRIP		
C	Sunday, May 8, 2016	STO2	Kuzma, Dan
O 1700	ACTUAL START DATE/TIME: 05/08/2016 1700 ACTUAL END DATE/TIME: 05/08/2016 2220 STATION: LETELLIER EQUIPMENT: LINE 41 REMARKS :		
	Sunday, May 8, 2016	NSSS	Scott, Derek
1814	SWITCHING 16-06215-OO WAS DELAYED DUE TO DIFFICULTY IN REACHING ON CALL STAFF FOR STEINBACH CSC Sunday, May 8, 2016		
	Sunday, May 8, 2016	GNSO	Whynot, Thomas
1838	DORSEY CALLED TO INFORM US THA THEIR DIW SYSTEM WAS APPROACHING TEMPERATURES CLOSE TO THE TRIPPING POINT OF VG42. WITH THAT INFORMATION, GRAND RAPIDS WAS RAMPED UP TO BACK DOWN ON LIMESTONE GENERATION BY APPROX 100 MW. DORSEY DIW WAS THEN COOLED DOWN, AND THE TRIP OF VG42 WAS AVERTECD.		
	Sunday, May 8, 2016	GNSO	Gerald, Ross
O 1908	GEOMAGNETIC DISTURBANCE WARNING OF A K7 OR HIGHER EVENT VALID FROM 1855 EST TO 2300 EST Sunday, May 8, 2016		
	Sunday, May 8, 2016	TSSS	Scott Saboraki
1945	SPOKE TO SCC STANDBY JEFF BLOODWORTH AND INFORMED HIM OF THE NEW K-7 SMD WARNING THRU 2300 EST TONITE. . INFORMED JEFF THAT SCHEDULES WERE FORECASTED TO BE BELOW 1700 USA SOUTH AND THAT POLE 3 WAS IN THE PROCESS OF BEING RETURNED AHEAD OF SCHEDULE.		
	Sunday, May 8, 2016	SPSO	Ron Warcimaga
O 2159	GEOMAGNETIC ALERT ISSUED @ 21:59; K7 THRESHOLD HAS BEEN REACHED. Sunday, May 8, 2016		
	Sunday, May 8, 2016	GSO	Ray Berendse

Manitoba Hydro

Dispatch Log: All

Between 05/08/2016 0000 And 05/08/2016 2359

<i>Time</i>	<i>Log Entry</i>		
O 2303	ACTUAL START DATE/TIME: 05/07/2016 0400 ACTUAL END DATE/TIME: 05/08/2016 2303 STATION: DORSEY EQUIPMENT: POLE 3 RCM REMARKS : PARENT ORDER 16-00427-OO DORSEY POLE 3 RCM CLEARANCES REQUIRED HAVE BEEN INCLUDED ON COVER PAGE CHILD ORDER 16-00429-OO HENDAY DC 1-3 RCM CLEARANCES REQUIRED HAVE BEEN INCLUDED ON THE PARENT REQUEST COVER PAGE CHILD ORDER 16-00428-OO HENDAY POLE 3 RCM CLEARANCES REQUIRED HAVE BEEN INCLUDED ON THE PARENT REQUEST COVER PAGE CHILD ORDER 16-05107-OO THOMPSON HLT DC-1 TO BE REPLACING BROKEN INSULATORS BETWEEN RADISSON – STR 840, CLEARANCES REQUIRED HAVE BEEN INCLUDED ON PARENT COVER PAGE CHILD ORDER 16-05809-OO SELKIRK HLT ON DC 1 TO BE REPLACING BROKEN INSULATORS ON STRUCTURES #1217 AND #1319 Sunday, May 8, 2016 NSSS Day, Eric		
H 2359	DAILY TOTALS: IMPORT: 5205 MW EXPORT: 43844 MW EM CALLS: 0 TLR: 0 Sunday, May 8, 2016 GSO Ray Berendse		